

- 2. NO CONCRETE FLOOR ALLOWED IN METER PIT.
- METER PIT SHALL BE CONSTRUCTED OF ANY COMBINATION OF CONCRETE RINGS TOTAL – 48" IN LENGTH.
- 4. ADJUSTMENT RINGS SHALL BE 2", 3", 4" OR 6" IN HEIGHT AND SHALL BE INSERTED BETWEEN THE DOME AND TOP RING.
- 5. NO CONNECTIONS OR CHANGES IN PIPE DIAMETER SHALL BE MADE FROM THE MAIN TAP TO A DISTANCE OF FIVE FEET BEYOND THE METER PIT WALL ON THE OUTLET SIDE.
- 6. LID SHALL SAY "WATER METER"

METER SIZE	Α	В	C	D
5/8"x 3/4"	12-5/8"	7-13/16"	7-13/16"	4"
3/4"	14-1/4"	9-5/16"	8-15/16"	5"
1"	17-1/4"	11-1/16"	11-1/4"	6"

SHEET 1 OF 2



STANDARDS & SPECIFICATIONS

REVISED:

OUTSIDE SETTING

1" METERS

AND BELOW

DATE:

DRAWING NO. 200-12